

Part III : Technical Specification POS A)

General Data

GasLine industrial gas CHP set, type GLC 62I B.

Output	kVA	: 249
	kWe	: 200
Frequency	Hz	: 50
Air temperature	°C	: 25

COP, Continuous power

For continuous operation at a constant load for unlimited number of hours per year. Power definition according to ISO 8528. Power test code ISO 3046.

Reference conditions

Atmospheric conditions		
Barometric pressure	hPa	: 1000
Relative humidity	%	: 30
Fuel		
Energy value	kJ/m3	: 31000
Density	kg/dm	: 0,67
Methane Number		: 80 *)

*) Note:

Output determined as per above is called sold output and is what is stated in Technical Data and Brochures. Deviating figures may cause output corrections.

Part III : Technical Specification POS A)

Engine Data

Water-cooled, 4-stroke, lean-burn gas engine with turbo charger and intercooler:

Engine		: SCANIA
Type		: SGI-I3
Power output *)	kW	: 215
Speed	rpm	: 1500
Cycle		: D2
Number of cylinders		: 6 in line
Displacement	dm3	: 12,7
Bore x stroke	mm	: 130 x 160
Compression ratio		: 12,6 : 1

*) Outputs have been determined under given test conditions according to the international performance standard ISO 3046.

Fuel system

Electronically adjustable air/fuel mixer.
Throttle valve with actuator.
Speed control.
Heavy duty industrial ignition system with controller.
One ignition coils per cylinder.
Sparkplugs for industrial use.
Gas fuel train build on set with stainless steel hose to mixer, 40-50 mBar inlet pressure.

Lub oil system

Full flow lub oil filter.
Gear driven lub oil pump.
Lub oil cooler.
Piston cooling by oil nozzles.
Lub oil drain pump.
Lub oil level monitoring system consisting of:
- oil level controller.
- lub oil tank, capacity 22 litre.

Air inlet system

Engine mounted air cleaner.

Part III : Technical Specification POS A)

Exhaust system

Dry exhaust manifold.
Turbo charger.
90° exhaust bend including flanges and gaskets.
Exhaust compensator with flange.
Exhaust gas temperature sensor (PT-200) for every cylinder.
Stainless steel silencer 6 " 35 dB(A) set mounted.

Cooling system

Engine water coolers.
Exhaust gas cooler set mounted.
Jacket water heater temperature controlled including ON/OFF switch.

Electrical system

Electric starter, 24 V, single poled.
Battery charger, 24 V, 16 Amp, build on the control box frame.
Battery container, integrated in the genset frame.
Starter batteries, 2x 12V with cold cranking amps >800 Amp, maintenance free types.

Several

Flywheel housing SAE I.
Flywheel, I4.
Internal crankcase ventilation.
Protection covers for all moving parts.
Separate 4-valve cylinderhead for each cylinder.
Gear train at flywheel side of the engine.

Part III : Technical Specification POS A)

Alternator Data

Alternator		: STAMFORD
Type		: HCI 434 D
Insulation class		: H
Temperature rise class		: H at 40 °C ambient temperature
Voltage	V	: 380, 400, 415 or 440
		: 3-phase serie star winding no. 311/312
Frequency	Hz	: 50
Load factor		: 0,8
Protection		: IP23
Short circuit current		: 300%

Scope of supply includes:

SAE adaptor flange.

Single bearing.

Anti-condensation heater.

AVR control system type MX-34I.

Part III : Technical Specification POS A)

Engine Control and Monitoring System

General

All-In-One engine controller is mounted in a control box.

Key switch mounted in the control box.

Control box mounted left hand side of skid.

Wiring and sensors mounted on the engine including cable harness to control box.

Engine controller

All-In-One is a dedicated controller for genset applications. It controls, monitors and protects the gas engine and alternator. The controller is equipped with a powerful graphic display with icons, symbols and bar graphs for intuitive operation, which together with high functionality sets new standards in engine controls.

Engine functions

- engine control
- engine monitoring and protections
- speed measurement
- running hours counter
- voltage monitoring starter batteries
- number of start attempts registration
- on screen alarm list indication
- event and time driven engine history for back tracing
- binary, analogue and CAN engine communication
- languages selectable
- MODBUS communication selectable

Generator functions

- Generator Circuit breaker control
- Main circuit breaker control
- Synchronization

Monitoring system

Alarms consisting of:

- alarm cooling water temperature (high)
- alarm cooling water level (low)
- alarm lub oil pressure engine (low)
- alarm lub oil temperature engine (high)

Engine shut down consisting of:

- cooling water temperature (high high)
- lub oil pressure engine (low low)
- overspeed (high)

Generator monitoring consisting of:

- 3 phase monitoring
- Over/Under Frequency
- Over/Under voltage

Part III : Technical Specification POS A)

- Overload protection

Distribution board

Distribution board, 630 Amp, set mounted, consisting of:

- MCCB switch
- Thermal protection
- Motor drive
- Feedback signal
- G59 relais (for sets in UK only)

Several

AVRi interface Module.

Parallel operation

Genset suited for parallel operation including:

- automatic synchronising and breaker control integrated in All-In-One controller.
- droop trafo in alternator.

Part III : Technical Specification POS A)

Assembly

Frame and assembly

Engine and alternator flexible mounted on a common base frame.

Frame painted black and provided with:

- drip tray
- drain plug
- mounting strips for electrical wiring
- 6-point support for the genset

Acoustic enclosure voor inside placement.

Test run and classification

Genset tested on Sandfirden test bench, and contains

- FAT and performance test according to test protocol
- acceptance by class (if applicable)
- alarm and shut down test
- parallel running (optional)
- final check before delivery

Finishing

Genset painted in Sandfirden blue (RAL 5010).

Set provided with warning stickers and hoisting instructions.

Genset sealed in plastic.

Part III : Technical Specification POS A)

Miscellaneous

Commissioning

Commissioning in Europe, per set one (1) man for three (3) days, including travelling and lodging.

Warranty

8000 Running hours or twelve (12) months after start-up, but not beyond eighteen (18) months after delivery from Suppliers plant, whichever occurs first. For more information we refer to our Terms and Conditions 20070418Ec.